

ANNUAL REPORT 2012-2013

CHIEF
DRINKING WATER
INSPECTOR

APPENDICES

INSPECTION RATINGS AND DRINKING WATER QUALITY RESULTS

2

Appendix 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

ORDERS

21

Appendix 2-A-1: Summary of Municipal Residential Drinking Water Systems Receiving Contravention Orders as a Result of an Inspection in 2012-13

21

Appendix 2-A-2: Summary of Municipal Residential Drinking Water Systems Receiving Contravention Orders as a Result of an Incident in 2012-13

22

Appendix 2-B: Summary of Municipal Residential Drinking Water Systems Receiving Preventative Measures Orders as a Result of an Incident in 2012-13

23

Appendix 2-C-1: Summary of Laboratories Licensed to Perform Drinking Water Testing Receiving Contravention Orders in 2012-13

23

Appendix 2-C-2: Summary of Non-licensed Facilities Receiving Contravention Orders in 2012-13

CONVICTIONS

24

Appendix 3: Summary of Municipal Residential Drinking Water System Convictions – April 1, 2012 to March 31, 2013

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Adjala-Tosorontio, Township of	Colgan Drinking Water System	100.00%	100.00%
Adjala-Tosorontio, Township of	Everett Drinking Water System	100.00%	100.00%
Adjala-Tosorontio, Township of	Hockley Drinking Water System	100.00%	100.00%
Adjala-Tosorontio, Township of	Lisle Drinking Water System	100.00%	100.00%
Adjala-Tosorontio, Township of	Loretto Heights Drinking Water System	100.00%	100.00%
Adjala-Tosorontio, Township of	Rosemont Drinking Water System	100.00%	100.00%
Adjala-Tosorontio, Township of	Weca Drinking Water System	100.00%	100.00%
Ajax, Town of	Oshawa-Whitby-Ajax Drinking Water System-Ajax	100.00%	99.81%
Alfred and Plantagenet, Township of	Lefaire and Plantagenet Drinking Water System	100.00%	100.00%
Alfred and Plantagenet, Township of	Wendover Drinking Water System	100.00%	99.23%
Alnwick/Haldimand, Township of	Grafton Drinking Water System	96.97%	100.00%
Amaranth, Township of	Waldemar Drinking Water System	95.68%	99.76%
Amherstburg, Town of	Amherstburg Drinking Water System	95.45%	100.00%
Armstrong, Township of	Earlton Drinking Water System	100.00%	100.00%
Arnprior, Town of	Arnprior Drinking Water System	100.00%	99.76%
Arran-Elderslie, Municipality of	Arran-Elderslie Drinking Water System	99.26%	100.00%
Arran-Elderslie, Municipality of	Tara Drinking Water System	96.65%	100.00%
Ashfield-Colborne-Wawanosh, Township of	Benmiller Drinking Water System	100.00%	97.30%
Ashfield-Colborne-Wawanosh, Township of	Century Heights Subdivision Drinking Water System	100.00%	98.44%
Ashfield-Colborne-Wawanosh, Township of	Courtney Subdivision Distribution System	100.00%	99.40%
Ashfield-Colborne-Wawanosh, Township of	Dungannon Drinking Water System	100.00%	99.41%
Ashfield-Colborne-Wawanosh, Township of	Huron Sands Drinking Water System	100.00%	96.15%
Ashfield-Colborne-Wawanosh, Township of	South Lucknow Distribution System	100.00%	99.45%
Asphodel-Norwood, Township of	Norwood Drinking Water System	100.00%	99.78%
Asphodel-Norwood, Township of	Trentview Estates Distribution System	100.00%	100.00%
Assiginack, Township of	Manitowaning Drinking Water System	100.00%	100.00%
Assiginack, Township of	Sunsite Estates Subdivision Drinking Water System	100.00%	100.00%
Atikokan, Township of	Atikokan Drinking Water System	87.66%	99.88%
Aurora, Town of	Town of Aurora Distribution System	98.18%	99.89%
Aurora, Town of	York Drinking Water System-Aurora	100.00%	100.00%
Aylmer, Town of	Aylmer Distribution System	95.16%	100.00%
Aylmer, Town of	Aylmer Secondary Area Water Supply System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Bancroft, Town of	Bancroft Drinking Water System	100.00%	100.00%
Barrie, City of	Barrie Drinking Water System	100.00%	99.95%
Bayham, Municipality of	Municipality of Bayham Distribution System	100.00%	100.00%
Belleville, City of	Belleville Drinking Water System	100.00%	99.84%
Belleville, City of	Point Anne Hamlet Drinking Water System	100.00%	98.40%
Billings, Township of	Kagawong Drinking Water System	100.00%	100.00%
Black River-Matheson, Township of	Holtyre Drinking Water System	100.00%	100.00%
Black River-Matheson, Township of	Matheson Drinking Water System	100.00%	100.00%
Black River-Matheson, Township of	Ramore Drinking Water System	100.00%	98.84%
Black River-Matheson, Township of	Val Gagne Drinking Water System	100.00%	100.00%
Blandford-Blenheim, Township of	Bright Drinking Water System	98.05%	100.00%
Blandford-Blenheim, Township of	Drumbo Drinking Water System	95.78%	100.00%
Blandford-Blenheim, Township of	Plattsville Drinking Water System	96.86%	99.77%
Blandford-Blenheim, Township of	Princeton Manor Cistern System	100.00%	100.00%
Blind River, Town of	Blind River Drinking Water System	98.29%	98.70%
Bluewater, Municipality of	Bluewater Lakeshore Distribution System	100.00%	99.74%
Bluewater, Municipality of	Carriage Lane Drinking Water System	97.62%	100.00%
Bluewater, Municipality of	Harbour Lights Drinking Water System	97.77%	98.77%
Bluewater, Municipality of	Hensall Distribution System	93.09%	100.00%
Bluewater, Municipality of	Zurich Drinking Water System	94.57%	100.00%
Bonnechere Valley, Township of	Eganville Drinking Water System	98.36%	99.65%
Bracebridge, Town of	Bracebridge (Kirby's Beach) Drinking Water System	100.00%	99.87%
Bradford West Gwillimbury, Town of	Bradford/Bondhead Drinking Water System	100.00%	100.00%
Brant, County of	Airport Drinking Water System	100.00%	100.00%
Brant, County of	Cainsville-King George Road Distribution System-Cainsville Distribution System	100.00%	100.00%
Brant, County of	Cainsville-King George Road Distribution System-King George Road Distribution System	100.00%	100.00%
Brant, County of	Mt. Pleasant Drinking Water System	95.98%	100.00%
Brant, County of	Paris Drinking Water System	99.21%	100.00%
Brant, County of	St. George Drinking Water System	100.00%	100.00%
Brantford, City of	City of Brantford Drinking Water System	92.71%	99.89%
Brighton, Municipality of	Brighton Springs Drinking Water System	98.46%	100.00%
Brock, Township of	Beaverton Drinking Water System	100.00%	100.00%
Brock, Township of	Cannington Drinking Water System	100.00%	100.00%
Brock, Township of	Sunderland Drinking Water System	100.00%	100.00%
Brockton, Municipality of	Chepstow Drinking Water System	100.00%	98.98%
Brockton, Municipality of	Lake Rosalind Drinking Water System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Brockton, Municipality of	Town of Hanover Drinking Water System	100.00%	99.83%
Brockton, Municipality of	Walkerton Drinking Water System	100.00%	98.62%
Brockville, City of	Brockville Drinking Water System	100.00%	99.92%
Brooke-Alvinston, Municipality of	Alvinston Distribution System	94.27%	100.00%
Bruce Mines, Town of	Bruce Mines Drinking Water System	95.67%	100.00%
Burk's Falls, Village of	Burk's Falls Drinking Water System	81.62%	100.00%
Burlington, City of	South Halton Drinking Water System-Bridgeview Community Distribution System	100.00%	100.00%
Burlington, City of	South Halton Drinking Water System-Burlington	100.00%	100.00%
Burlington, City of	South Halton Drinking Water System-North Aldershot Distribution System	100.00%	100.00%
Burlington, City of	South Halton Drinking Water System-Snake Road Distribution System	100.00%	100.00%
Caledon, Town of	Caledon Village and Alton Drinking Water System	100.00%	100.00%
Caledon, Town of	Cheltenham Drinking Water System	100.00%	100.00%
Caledon, Town of	Inglewood Drinking Water System	100.00%	100.00%
Caledon, Town of	Palgrave-Caledon East Drinking Water System	100.00%	100.00%
Callander, Municipality of	Callander Drinking Water System	85.89%	100.00%
Cambridge, City of	Cambridge Distribution System	100.00%	99.97%
Cambridge, City of	Region of Waterloo Drinking Water System-Cambridge	99.43%	100.00%
Carleton Place, Town of	Carleton Place Drinking Water System	100.00%	100.00%
Casselman, Village of	Casselman Drinking Water System	100.00%	100.00%
Cavan-Monaghan, Township of	Millbrook Drinking Water System	98.38%	100.00%
Central Elgin, Municipality of	Belmont Drinking Water System	100.00%	100.00%
Central Elgin, Municipality of	Central Elgin Distribution System	100.00%	99.94%
Central Elgin, Municipality of	Elgin Area Primary Water Supply System	90.54%	100.00%
Central Huron, Municipality of	Auburn Drinking Water System	98.12%	97.79%
Central Huron, Municipality of	Clinton Drinking Water System	100.00%	100.00%
Central Huron, Municipality of	Kelly Drinking Water System	100.00%	100.00%
Central Huron, Municipality of	McClinchey Drinking Water System	100.00%	100.00%
Central Huron, Municipality of	S.A.M. Drinking Water System	100.00%	100.00%
Central Huron, Municipality of	Van De Wetering Drinking Water System	100.00%	100.00%
Central Manitoulin, Municipality of	Mindemoya Drinking Water System	99.21%	100.00%
Centre Wellington, Township of	Centre Wellington Drinking Water System	100.00%	100.00%
Champlain, Township of	Laurentian Park Distribution System	100.00%	100.00%
Champlain, Township of	L'Orignal Distribution System	100.00%	98.20%
Champlain, Township of	Vankleek Hill Distribution System	100.00%	100.00%
Chapleau, Township of	Chapleau Drinking Water System	97.57%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Chapple, Township of	Barwick Drinking Water System	100.00%	100.00%
Charlton and Dack, Municipality of	Bradley Subdivision Distribution System	100.00%	96.55%
Charlton and Dack, Municipality of	Charlton Drinking Water System	100.00%	100.00%
Chatham-Kent, Municipality of	Bothwell Distribution System	100.00%	100.00%
Chatham-Kent, Municipality of	Chatham-Kent Drinking Water System-Chatham	97.89%	99.89%
Chatham-Kent, Municipality of	Chatham-Kent Drinking Water System-South Chatham-Kent	96.75%	99.91%
Chatham-Kent, Municipality of	Chatham-Kent Drinking Water System-Wallaceburg	100.00%	99.79%
Chatham-Kent, Municipality of	Chatham-Kent Drinking Water System-Wheatley	100.00%	100.00%
Chatham-Kent, Municipality of	Highgate Drinking Water System	99.47%	98.92%
Chatham-Kent, Municipality of	North Wallaceburg Distribution System	100.00%	100.00%
Chatham-Kent, Municipality of	Ridgetown Drinking Water System	95.79%	99.57%
Chatsworth, Township of	Chatsworth Drinking Water System	97.22%	100.00%
Chatsworth, Township of	Walter's Falls Drinking Water System	100.00%	100.00%
Clarence-Rockland, City of	Rockland Drinking Water System	100.00%	99.71%
Clarington, Municipality of	Bowmanville Drinking Water System	100.00%	100.00%
Clarington, Municipality of	Newcastle Drinking Water System	100.00%	99.93%
Clarington, Municipality of	Orono Drinking Water System	100.00%	100.00%
Clearview, Township of	Buckingham Woods Drinking Water System	96.88%	100.00%
Clearview, Township of	Colling-Woodlands Drinking Water System	96.91%	100.00%
Clearview, Township of	Creemore Drinking Water System	97.30%	100.00%
Clearview, Township of	New Lowell Drinking Water System	96.94%	99.77%
Clearview, Township of	Nottawa Drinking Water System	97.30%	99.71%
Clearview, Township of	Stayner Drinking Water System	97.30%	99.85%
Cobalt, Town of	Cobalt Drinking Water System	97.05%	99.80%
Cobourg, Town of	Cobourg Drinking Water System	100.00%	100.00%
Cochrane, Town of	Cochrane Drinking Water System	97.13%	100.00%
Coleman, Township of	Coleman Distribution System	100.00%	99.80%
Collingwood, Town of	Collingwood Drinking Water System	100.00%	99.78%
Cornwall, City of	Cornwall Drinking Water System	100.00%	99.89%
Cramahe, Township of	Colborne Drinking Water System	99.13%	100.00%
Dawn-Euphemia, Township of	Dawn-Euphemia Distribution System	94.63%	100.00%
Deep River, Town of	Deep River Drinking Water System	100.00%	100.00%
Deseronto, Town of	Deseronto Drinking Water System	100.00%	99.60%
Dryden, City of	Dryden Drinking Water System	94.82%	99.74%
Dubreuilville, Township of	Dubreuilville Drinking Water System	94.24%	100.00%
Dutton/Dunwich, Municipality of	Dutton-Dunwich Distribution System	100.00%	100.00%
Ear Falls, Township of	Ear Falls Drinking Water System	79.08%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
East Garafraxa, Township of	Marsville Subdivision Drinking Water System	95.91%	100.00%
East Gwillimbury, Town of	Holland Landing/Queensville/Sharon Distribution System	100.00%	99.83%
East Gwillimbury, Town of	Mount Albert Distribution System	100.00%	99.73%
East Gwillimbury, Town of	Mount Albert Drinking Water System	100.00%	100.00%
East Gwillimbury, Town of	Yonge-Green Lane Distribution System	100.00%	100.00%
East Gwillimbury, Town of	York Drinking Water System-Holland Landing	100.00%	100.00%
East Gwillimbury, Town of	York Drinking Water System-Queensville	100.00%	100.00%
East Luther Grand Valley, Township of	East Luther Grand Valley Drinking Water System	100.00%	99.71%
East Zorra-Tavistock, Township of	Hickson Drinking Water System	100.00%	100.00%
East Zorra-Tavistock, Township of	Innerkip Drinking Water System	96.98%	99.73%
East Zorra-Tavistock, Township of	Tavistock Drinking Water System	96.94%	100.00%
Edwardsburgh/Cardinal, Township of	Bennett Street Drinking Water System	95.58%	100.00%
Edwardsburgh/Cardinal, Township of	Cardinal Drinking Water System	100.00%	100.00%
Edwardsburgh/Cardinal, Township of	Edwardsburgh Industrial Park Distribution System	100.00%	100.00%
Elizabethtown-Kitley, Township of	Elizabethtown-Kitley Distribution System	100.00%	99.92%
Elliot Lake, City of	Elliot Lake Drinking Water System	95.96%	99.57%
Emo, Township of	Emo Drinking Water System	95.08%	100.00%
Englehart, Town of	Englehart Drinking Water System	100.00%	99.78%
Enniskillen, Township of	Enniskillen Township Distribution System	100.00%	100.00%
Erin, Town of	Erin Drinking Water System	100.00%	100.00%
Erin, Town of	Hillsburgh Drinking Water System	100.00%	100.00%
Espanola, Town of	Espanola Drinking Water System	100.00%	100.00%
Essa, Township of	Angus Drinking Water System	98.97%	100.00%
Essa, Township of	Baxter Distribution System	94.73%	100.00%
Essa, Township of	Glen Avenue (Thornton) Drinking Water System	98.85%	100.00%
Essex, Town of	Essex Drinking Water System-Essex Distribution System	100.00%	100.00%
Essex, Town of	Essex Drinking Water System-Harrow-Colchester South	100.00%	100.00%
Fauquier-Strickland, Township of	Fauquier Drinking Water System	96.82%	99.24%
Fort Erie, Town of	Fort Erie Distribution System	100.00%	99.58%
Fort Erie, Town of	Rosehill Drinking Water System	100.00%	99.44%
Fort Frances, Town of	Fort Frances Drinking Water System	95.56%	99.89%
Front of Yonge, Township of	Miller Manor Apartments Drinking Water System	90.76%	100.00%
Galway-Cavendish and Harvey, Township of	Alpine/Pirates Glen Drinking Water System	100.00%	100.00%
Galway-Cavendish and Harvey, Township of	Buckhorn Lake Estates Drinking Water System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Gananoque, Town of	James W. King Drinking Water System	98.38%	99.62%
Georgian Bay, Township of	Mactier (Beech) Drinking Water System	100.00%	99.80%
Georgian Bay, Township of	Port Severn (Lone Pine) Drinking Water System	100.00%	100.00%
Georgian Bluffs, Township of	East Linton Drinking Water System	100.00%	100.00%
Georgian Bluffs, Township of	Oxenden Distribution System	100.00%	100.00%
Georgian Bluffs, Township of	Pottawatomi Drinking Water System	89.80%	100.00%
Georgian Bluffs, Township of	Shallow Lake Drinking Water System	97.15%	100.00%
Georgina, Town of	Georgina Drinking Water System-Georgina	100.00%	100.00%
Georgina, Town of	Georgina Drinking Water System-Keswick	100.00%	100.00%
Georgina, Town of	Keswick-Sutton Distribution System	100.00%	99.85%
Goderich, Town of	Goderich Drinking Water System	100.00%	100.00%
Gore Bay, Town of	Gore Bay Drinking Water System	100.00%	100.00%
Gravenhurst, Town of	Gravenhurst (Muskoka Beach) Drinking Water System	100.00%	100.00%
Greater Napanee, Town of	A.L. Dafoe Drinking Water System	100.00%	100.00%
Greater Napanee, Town of	Sandhurst Shores Drinking Water System	100.00%	99.27%
Greater Sudbury, City of	Dowling Drinking Water System	100.00%	100.00%
Greater Sudbury, City of	Falconbridge Drinking Water System	100.00%	100.00%
Greater Sudbury, City of	Onaping/Levack Drinking Water System	100.00%	100.00%
Greater Sudbury, City of	Sudbury Drinking Water System-David St.	100.00%	99.81%
Greater Sudbury, City of	Sudbury Drinking Water System-Garson	100.00%	99.85%
Greater Sudbury, City of	Sudbury Drinking Water System-Wahnapitei	100.00%	99.88%
Greater Sudbury, City of	Valley Drinking Water System	96.35%	99.89%
Greater Sudbury, City of	Vermilion Drinking Water System	100.00%	100.00%
Greater Sudbury, City of	Vermillion Distribution System	100.00%	99.82%
Greenstone, Municipality of	Beardmore Drinking Water System	100.00%	100.00%
Greenstone, Municipality of	Caramat Drinking Water System	100.00%	100.00%
Greenstone, Municipality of	Geraldton Drinking Water System	64.62%	99.55%
Greenstone, Municipality of	Longlac Drinking Water System	91.39%	100.00%
Greenstone, Municipality of	Nakina Drinking Water System	87.48%	100.00%
Grey Highlands, Municipality of	Kimberley-Amik-Talisman Drinking Water System	97.29%	100.00%
Grey Highlands, Municipality of	Markdale Drinking Water System	95.74%	100.00%
Grimsby, Town of	Grimsby Distribution System	100.00%	99.93%
Grimsby, Town of	Grimsby Drinking Water System	96.92%	100.00%
Guelph, City of	Guelph Drinking Water System	96.40%	99.96%
Guelph/Eramosa, Township of	Gazer Mooney Subdivision Distribution System	100.00%	100.00%
Guelph/Eramosa, Township of	Hamilton Drive Drinking Water System	100.00%	100.00%
Guelph/Eramosa, Township of	Rockwood Drinking Water System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Haldimand County	Caledonia and Cayuga Distribution System	100.00%	99.62%
Haldimand County	Dunnville Drinking Water System	97.86%	99.89%
Haldimand County	Nanticoke Drinking Water System	100.00%	99.78%
Halton Hills, Town of	Acton Drinking Water System	100.00%	100.00%
Halton Hills, Town of	Georgetown Drinking Water System	100.00%	99.96%
Hamilton, City of	Carlisle Drinking Water System	100.00%	100.00%
Hamilton, City of	Freelton Drinking Water System	100.00%	99.89%
Hamilton, City of	Greensville Drinking Water System	100.00%	99.80%
Hamilton, City of	Hamilton Drinking Water System-Fifty Road Distribution System	100.00%	100.00%
Hamilton, City of	Hamilton Drinking Water System-Woodward	100.00%	99.94%
Hamilton, City of	Lynden Drinking Water System	100.00%	100.00%
Hamilton, Township of	Camborne Drinking Water System	96.76%	100.00%
Hamilton, Township of	Creighton Heights Drinking Water System	100.00%	100.00%
Hamilton, Township of	Hamilton Township Distribution System	100.00%	100.00%
Havelock-Belmont-Methuen, Township of	Havelock Drinking Water System	99.06%	100.00%
Hawkesbury, Town of	Hawkesbury Drinking Water System	100.00%	99.90%
Hearst, Town of	Hearst Drinking Water System	100.00%	99.68%
Highlands East, Municipality of	Cardiff Drinking Water System	100.00%	99.77%
Highlands East, Municipality of	Dyno Estates Drinking Water System	100.00%	100.00%
Hilton Beach, Village of	Hilton Beach Drinking Water System	100.00%	100.00%
Hornepayne, Township of	Herbert Avenue Drinking Water System	100.00%	99.79%
Huntsville, Town of	Huntsville (Fairview) Drinking Water System	100.00%	99.77%
Huntsville, Town of	Port Sydney (Clarke Well) Drinking Water System	100.00%	100.00%
Huron East, Municipality of	Brucefield Drinking Water System	100.00%	100.00%
Huron East, Municipality of	Brussels Drinking Water System	100.00%	100.00%
Huron East, Municipality of	Seaforth Drinking Water System	100.00%	100.00%
Huron East, Municipality of	Vanastra Distribution System	100.00%	100.00%
Huron-Kinloss, Township of	Huronville Subdivision Distribution System	100.00%	100.00%
Huron-Kinloss, Township of	Lakeshore Drinking Water System	100.00%	99.40%
Huron-Kinloss, Township of	Lucknow Drinking Water System	100.00%	99.45%
Huron-Kinloss, Township of	Ripley Drinking Water System	100.00%	99.51%
Huron-Kinloss, Township of	Whitechurch Drinking Water System	95.62%	99.48%
Ignace, Township of	Ignace Drinking Water System	100.00%	100.00%
Ingersoll, Town of	Ingersoll Drinking Water System	96.03%	100.00%
Innisfil, Town of	Alcona Drinking Water System	100.00%	100.00%
Innisfil, Town of	Churchill Drinking Water System	100.00%	99.49%
Innisfil, Town of	Cookstown Drinking Water System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Innisfil, Town of	Goldcrest Drinking Water System	100.00%	100.00%
Innisfil, Town of	Golf Haven Drinking Water System	100.00%	Not available ¹
Innisfil, Town of	Innisfil Heights Drinking Water System	100.00%	100.00%
Innisfil, Town of	Stroud Drinking Water System	100.00%	99.62%
Iroquois Falls, Town of	Iroquois Falls Drinking Water System	100.00%	99.78%
Iroquois Falls, Town of	Monteith Correctional Complex Drinking Water System	100.00%	100.00%
Iroquois Falls, Town of	Monteith Distribution System	100.00%	100.00%
Iroquois Falls, Town of	Porquis Junction Drinking Water System	100.00%	100.00%
James, Township of	Elk Lake Drinking Water System	100.00%	98.88%
Johnson, Township of	Desbarats Drinking Water System	100.00%	100.00%
Kapuskasing, Town of	Kapuskasing Drinking Water System	100.00%	99.63%
Kawartha Lakes, City of	Birchpoint Estates Drinking Water System	96.89%	100.00%
Kawartha Lakes, City of	Bobcaygeon Drinking Water System	99.41%	99.81%
Kawartha Lakes, City of	Canadiana Shores Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Fenelon Falls Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Janetville Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	King's Bay Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Kinmount Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Lindsay Drinking Water System	95.50%	99.94%
Kawartha Lakes, City of	Manilla Drinking Water System	96.77%	100.00%
Kawartha Lakes, City of	Manorview Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Mariposa Estates Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Norland Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Omeme Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Pinewood Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Pleasant Point Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Sonya Village Subdivision Drinking Water System	93.47%	100.00%
Kawartha Lakes, City of	Southview Estates Drinking Water System	100.00%	99.77%
Kawartha Lakes, City of	Victoria Place Drinking Water System	100.00%	100.00%
Kawartha Lakes, City of	Western Trent/Palmina Drinking Water System	93.22%	100.00%
Kawartha Lakes, City of	Woodfield Drinking Water System	95.75%	100.00%
Kawartha Lakes, City of	Woodville Drinking Water System	100.00%	100.00%
Kenora, City of	Kenora Area Drinking Water System	87.01%	99.80%
Killaloe, Hagarty and Richards, Township of	Killaloe Drinking Water System	100.00%	99.28%
Killarney, Municipality of	Killarney Drinking Water System	96.89%	100.00%
Kincardine, Municipality of	Armow Drinking Water System	100.00%	100.00%

¹ Drinking water quality data is not available for this system as it ceased operations in the 2011-12 fiscal year.

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Kincardine, Municipality of	Kincardine Drinking Water System	100.00%	99.86%
Kincardine, Municipality of	Scott Point Drinking Water System	100.00%	100.00%
Kincardine, Municipality of	Tiverton Drinking Water System	95.82%	100.00%
Kincardine, Municipality of	Underwood Drinking Water System	100.00%	100.00%
King, Township of	Ansnoerveldt Distribution System	88.00%	99.55%
King, Township of	Ansnoerveldt Drinking Water System	100.00%	100.00%
King, Township of	King City Distribution System	91.03%	99.80%
King, Township of	King City Drinking Water System	100.00%	100.00%
King, Township of	Nobleton Distribution System	100.00%	99.53%
King, Township of	Nobleton Drinking Water System	100.00%	100.00%
King, Township of	Schomberg Distribution System	91.03%	99.70%
King, Township of	Schomberg Drinking Water System	100.00%	100.00%
Kingston, City of	Cananda Drinking Water System	100.00%	98.68%
Kingston, City of	Kingston Drinking Water System-King Street	100.00%	99.91%
Kingston, City of	Kingston Drinking Water System-Point Pleasant	100.00%	100.00%
Kingsville, Town of	Kingsville Distribution System	100.00%	100.00%
Kingsville, Town of	Union Area Water Supply System	100.00%	100.00%
Kirkland Lake, Town of	Kirkland Lake Drinking Water System	100.00%	100.00%
Kitchener, City of	Kitchener Distribution System	87.61%	99.70%
Kitchener, City of	Region of Waterloo Drinking Water System-Kitchener	100.00%	100.00%
Kitchener, City of	Region of Waterloo Drinking Water System-Mannheim	100.00%	100.00%
Lake of Bays, Township of	Birch Glen (Baysville) Drinking Water System	100.00%	100.00%
Lakeshore, Town of	Town of Lakeshore Drinking Water System	100.00%	100.00%
Lakeshore, Town of	Town of Lakeshore Drinking Water System-Stoney Point	97.58%	99.88%
Lakeshore, Town of	Town of Lakeshore Drinking Water System-Tecumseh Distribution System	100.00%	100.00%
Lakeshore, Town of	Town of Lakeshore Drinking Water System-Union Distribution System	100.00%	100.00%
Lambton Shores, Municipality of	East Lambton Shores Distribution System	84.74%	99.94%
Lambton Shores, Municipality of	West Lambton Shores Distribution System	86.79%	99.81%
Larder Lake, Township of	Larder Lake Drinking Water System	100.00%	100.00%
LaSalle, Town of	Town of LaSalle Distribution System	100.00%	100.00%
Latchford, Town of	Latchford Drinking Water System	96.77%	100.00%
Laurentian Hills, Town of	Chalk River Drinking Water System	100.00%	99.60%
Laurentian Valley, Township of	Laurentian Valley Distribution System	100.00%	99.56%
Leamington, Municipality of	Leamington Distribution System-Union Distribution System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Leamington, Municipality of	Leamington Distribution System-Wheatley Distribution System	100.00%	100.00%
Leeds and the Thousand Islands, Township of	Lansdowne Drinking Water System	100.00%	100.00%
Lincoln, Town of	Beamsville Distribution System	100.00%	99.28%
Lincoln, Town of	Jordan-Vineland Distribution System	100.00%	99.82%
London, City of	City of London Distribution System	95.83%	99.88%
Loyalist, Township of	Bath Drinking Water System	100.00%	99.83%
Loyalist, Township of	Fairfield Drinking Water System	100.00%	99.91%
Lucan Biddulph, Township of	Lucan Biddulph Distribution System	91.11%	100.00%
Macdonald, Meredith and Aberdeen Additional, Township of	Echo Bay Drinking Water System	96.84%	100.00%
Machin, Township of	Vermilion Bay Drinking Water System	99.45%	100.00%
Madawaska Valley, Township of	Barry's Bay Drinking Water System	100.00%	99.60%
Madoc, Township of	Madoc Drinking Water System	100.00%	100.00%
Malahide, Township of	Malahide Distribution System	100.00%	99.70%
Malahide, Township of	Port Burwell Area Secondary Water Supply System	100.00%	100.00%
Manitouwadge, Township of	Manitouwadge Drinking Water System	100.00%	100.00%
Mapleton, Township of	Drayton Drinking Water System	100.00%	100.00%
Mapleton, Township of	Moorefield Drinking Water System	100.00%	100.00%
Marathon, Town of	Marathon Drinking Water System	98.29%	100.00%
Markham, Town of	Markham Distribution System	100.00%	99.82%
Markham/Richmond Hill/Vaughan, Municipalities of	York Drinking Water System-York Distribution System	100.00%	100.00%
Markstay-Warren, Municipality of	Markstay Distribution System	94.56%	98.83%
Markstay-Warren, Municipality of	Warren Drinking Water System	100.00%	100.00%
Marmora and Lake, Municipality of	Deloro Drinking Water System	100.00%	100.00%
Marmora and Lake, Municipality of	Marmora Drinking Water System	100.00%	100.00%
Matachewan, Township of	Matachewan Drinking Water System	100.00%	99.13%
Mattawa, Town of	Mattawa Drinking Water System	100.00%	100.00%
Mattice-Val Côté, Township of	Mattice Drinking Water System	100.00%	99.49%
McDougall, Township of	McDougall Nobel Distribution System	100.00%	100.00%
McGarry, Township of	Virginiatown-Kearns Drinking Water System	100.00%	100.00%
Meaford, Municipality of	Leith Distribution System	99.22%	100.00%
Meaford, Municipality of	Meaford Drinking Water System	96.24%	100.00%
Merrickville-Wolford, Village of	Merrickville Drinking Water System	100.00%	99.73%
Middlesex Centre, Municipality of	Birr Drinking Water System	99.45%	100.00%
Middlesex Centre, Municipality of	Melrose Drinking Water System	97.15%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Middlesex Centre, Municipality of	Middlesex Centre Distribution System-Middlesex Centre Distribution System	100.00%	100.00%
Midland, Town of	Midland Drinking Water System	99.49%	100.00%
Milton, Town of	Campbellville Drinking Water System	100.00%	100.00%
Milton, Town of	South Halton Drinking Water System-Milton	100.00%	99.94%
Minden Hills, Township of	Lutterworth Pines Drinking Water System	96.83%	100.00%
Minden Hills, Township of	Minden Drinking Water System	100.00%	100.00%
Minto, Town of	Clifford Drinking Water System	100.00%	100.00%
Minto, Town of	Harriston Drinking Water System	100.00%	100.00%
Minto, Town of	Minto Pines Subdivision Drinking Water System	99.39%	100.00%
Minto, Town of	Palmerston Drinking Water System	100.00%	100.00%
Mississauga, City of	South Peel Drinking Water System-Lakeview	98.72%	99.94%
Mississauga, City of	South Peel Drinking Water System-Lorne Park	97.40%	99.79%
Mississippi Mills, Town of	Mississippi Mills Drinking Water System	100.00%	100.00%
Mono, Town of	Cardinal Woods Drinking Water System	94.72%	100.00%
Mono, Town of	Island Lake Drinking Water System	95.87%	100.00%
Montague, Township of	Montague Distribution System	98.23%	100.00%
Moonbeam, Township of	Moonbeam Drinking Water System	93.69%	100.00%
Moosonee, Town of	Moosonee Drinking Water System	100.00%	100.00%
Morris-Turnberry, Municipality of	Belgrave Drinking Water System	100.00%	99.70%
Mulmur, Township of	Mansfield Drinking Water System	93.45%	100.00%
Muskoka Lakes, Township of	Bala (Minto) Drinking Water System	100.00%	100.00%
Muskoka Lakes, Township of	Port Carling (Ferndale) Drinking Water System	100.00%	99.80%
Nairn and Hyman, Township of	Nairn Centre Drinking Water System	100.00%	100.00%
New Tecumseth, Town of	Alliston Drinking Water System	98.41%	100.00%
New Tecumseth, Town of	Tottenham Drinking Water System	98.37%	99.37%
Newbury, Village of	Newbury (West Elgin Area Water Supply) Distribution System	100.00%	100.00%
Newmarket, Town of	Newmarket Distribution System	100.00%	99.92%
Newmarket, Town of	York Drinking Water System-Newmarket	100.00%	100.00%
Niagara Falls, City of	City of Niagara Falls Distribution System	89.32%	99.89%
Niagara Falls, City of	Decew Falls-Niagara Falls Drinking Water System-Niagara Falls	100.00%	99.73%
Niagara-on-the-Lake, Town of	Bevan Heights Distribution System	96.71%	100.00%
Niagara-on-the-Lake, Town of	Niagara-on-the-Lake Distribution System	88.07%	99.71%
Nipigon, Township of	Nipigon Drinking Water System	93.86%	100.00%
Norfolk County	Delhi Drinking Water System	100.00%	100.00%
Norfolk County	Port Dover Drinking Water System	97.15%	99.59%
Norfolk County	Port Rowan Drinking Water System	100.00%	99.81%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Norfolk County	Simcoe Drinking Water System	100.00%	100.00%
Norfolk County	Waterford Drinking Water System	100.00%	99.81%
North Bay, City of	North Bay Drinking Water System	94.91%	100.00%
North Dumfries, Township of	Ayr Drinking Water System	100.00%	99.85%
North Dumfries, Township of	Branchton Drinking Water System	100.00%	100.00%
North Dumfries, Township of	Region of Waterloo Drinking Water System-Lloyd Brown Distribution System	100.00%	99.19%
North Dumfries, Township of	Roseville Drinking Water System	100.00%	100.00%
North Dundas, Township of	Chesterville Drinking Water System	100.00%	99.87%
North Dundas, Township of	Winchester Drinking Water System	Not available ²	100.00%
North Glengarry, Township of	Alexandria Drinking Water System	100.00%	99.63%
North Glengarry, Township of	Glen Robertson Drinking Water System	100.00%	100.00%
North Grenville, Municipality of	Kemptville Drinking Water System	100.00%	99.61%
North Huron, Township of	Blyth Drinking Water System	96.98%	99.55%
North Huron, Township of	Wingham Drinking Water System	96.87%	100.00%
North Middlesex, Municipality of	North Middlesex Distribution System	88.33%	100.00%
North Perth, Municipality of	Atwood Drinking Water System	96.90%	100.00%
North Perth, Municipality of	Gowanstown Subdivision Drinking Water System	100.00%	100.00%
North Perth, Municipality of	Listowel Drinking Water System	96.97%	99.70%
North Perth, Municipality of	Molesworth Drinking Water System	100.00%	100.00%
North Stormont, Township of	Crysler Drinking Water System	100.00%	100.00%
North Stormont, Township of	Finch Drinking Water System	100.00%	100.00%
North Stormont, Township of	Moose Creek Drinking Water System	100.00%	100.00%
Northeastern Manitoulin and The Islands, Town of	Little Current Drinking Water System	100.00%	100.00%
Northeastern Manitoulin and The Islands, Town of	Sheguiandah Drinking Water System	100.00%	100.00%
Northern Bruce Peninsula, Municipality of	Lion's Head Drinking Water System	100.00%	100.00%
Norwich, Township of	Norwich Drinking Water System	98.41%	99.82%
Norwich, Township of	Otterville-Springford Drinking Water System	93.10%	99.57%
Oakville, Town of	South Halton Drinking Water System-Burloak	100.00%	100.00%
Oakville, Town of	South Halton Drinking Water System-Oakville	100.00%	100.00%
Oakville, Town of	South Halton Drinking Water System-South Halton Distribution System	100.00%	99.94%
Oil Springs, Village of	Oil Springs Water Distribution System	98.21%	100.00%
Oliver Paipoonge, Municipality of	Roslyn Village Subdivision Drinking Water System	95.64%	100.00%
Opasatika, Township of	Opasatika Drinking Water System	100.00%	100.00%

² Inspection rating is not available for this system as it was amalgamated with the Chesterville Drinking Water System.

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Orangeville, Town of	Orangeville Drinking Water System	92.87%	100.00%
Orillia, City of	Orillia Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Canterbury Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Cedar Brook Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Craighurst Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Harbourwood Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Horseshoe Highlands Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Maplewood Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Medonte Hills Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Robin Crest Drinking Water System	97.19%	99.75%
Oro-Medonte, Township of	Shanty Bay Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Sugar Bush Drinking Water System	100.00%	100.00%
Oro-Medonte, Township of	Warminster Drinking Water System	100.00%	100.00%
Oshawa, City of	Oshawa-Whitby-Ajax Drinking Water System-Oshawa	100.00%	99.87%
Otonabee-South Monaghan, Township of	Elgeti and Crystal Springs Subdivisions Drinking Water System	100.00%	100.00%
Otonabee-South Monaghan, Township of	Keene Heights Subdivision Drinking Water System	100.00%	100.00%
Ottawa, City of	Carp Drinking Water System	100.00%	99.89%
Ottawa, City of	Central Drinking Water System-Britannia	100.00%	99.74%
Ottawa, City of	Central Drinking Water System-Lemieux Island	100.00%	99.94%
Ottawa, City of	Kings Park Drinking Water System	100.00%	100.00%
Ottawa, City of	Munster Hamlet Drinking Water System	100.00%	100.00%
Ottawa, City of	Shadow Ridge Drinking Water System	96.82%	100.00%
Ottawa, City of	Vars Drinking Water System	100.00%	99.76%
Owen Sound, City of	Owen Sound Drinking Water System	96.21%	100.00%
Parry Sound, Town of	Parry Sound Drinking Water System	94.12%	100.00%
Pelham, Town of	Pelham Distribution System	100.00%	100.00%
Pembroke, City of	Pembroke Drinking Water System	100.00%	100.00%
Penetanguishene, Town of	Lepage Subdivision (Penetanguishene) Drinking Water System	100.00%	100.00%
Penetanguishene, Town of	Payette (Penetanguishene) Drinking Water System	100.00%	100.00%
Perth East, Township of	Milverton Drinking Water System	89.15%	100.00%
Perth East, Township of	Shakespeare Drinking Water System	90.77%	100.00%
Perth South, Township of	Sebringville Drinking Water System	89.56%	97.65%
Perth South, Township of	St. Pauls Drinking Water System	91.01%	97.87%
Perth, Town of	Perth Drinking Water System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Petawawa, Town of	Petawawa Drinking Water System	100.00%	99.44%
Peterborough, City of	Peterborough Drinking Water System	100.00%	99.87%
Petrolia, Town of	Petrolia Drinking Water System	85.46%	100.00%
Pickle Lake, Township of	Pickle Lake Drinking Water System	99.44%	100.00%
Plympton-Wyoming, Town of	Plympton-Wyoming Distribution System	100.00%	100.00%
Point Edward, Village of	Village of Point Edward Distribution System	95.09%	99.70%
Port Colborne, City of	Port Colborne Distribution System	100.00%	99.94%
Port Colborne, City of	Port Colborne Drinking Water System	100.00%	100.00%
Port Hope, Municipality of	Port Hope Drinking Water System	100.00%	100.00%
Powassan, Municipality of	Powassan Drinking Water System	87.45%	100.00%
Prescott, Town of	Prescott Drinking Water System	95.73%	100.00%
Prince Edward, County of	Ameliasburgh Hamlet Drinking Water System	100.00%	100.00%
Prince Edward, County of	Consecon/Carrying Place Distribution System	100.00%	99.23%
Prince Edward, County of	Fenwood Gardens/Rossmore Distribution System	100.00%	99.63%
Prince Edward, County of	Peats Point Subdivision Drinking Water System	100.00%	98.80%
Prince Edward, County of	Picton Drinking Water System	97.15%	99.84%
Prince Edward, County of	Wellington Drinking Water System	98.96%	99.59%
Quinte West, City of	Bayside Drinking Water System	94.84%	100.00%
Quinte West, City of	Frankford-Batawa Drinking Water System	100.00%	99.81%
Quinte West, City of	Trenton Drinking Water System	100.00%	99.90%
Rainy River, Town of	Rainy River Drinking Water System	100.00%	99.50%
Ramara, Township of	Bayshore Village Subdivision Drinking Water System	100.00%	100.00%
Ramara, Township of	Brechin & Lagoon City Drinking Water System	100.00%	100.00%
Ramara, Township of	Davy Drive Subdivision Drinking Water System	92.96%	100.00%
Ramara, Township of	Park Lane Subdivision Drinking Water System	100.00%	100.00%
Ramara, Township of	Somerset/ Knob Hill Distribution System	100.00%	100.00%
Ramara, Township of	South Ramara Drinking Water System	100.00%	100.00%
Ramara, Township of	Val Harbour Subdivision Drinking Water System	100.00%	100.00%
Red Lake, Municipality of	Balmertown Cochenour Mackenzie Island Drinking Water System	92.97%	100.00%
Red Lake, Municipality of	Madsen Drinking Water System	96.24%	100.00%
Red Lake, Municipality of	Red Lake Drinking Water System	100.00%	99.63%
Red Rock, Township of	Red Rock Drinking Water System	100.00%	100.00%
Renfrew, Town of	Renfrew Drinking Water System	100.00%	100.00%
Richmond Hill, Town of	Richmond Hill Distribution System	100.00%	99.87%
Russell, Township of	Russell Distribution System	93.09%	99.77%
Sables-Spanish Rivers, Township of	Massey Drinking Water System	100.00%	100.00%
Sarnia, City of	Lambton Area Water Supply System	84.58%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Sarnia, City of	Sarnia Distribution System	96.15%	99.86%
Saugeen Shores, Town of	Saugeen Shores Drinking Water System	100.00%	100.00%
Sault Ste. Marie, City of	Sault Ste. Marie Drinking Water System	99.08%	99.97%
Schreiber, Township of	Schreiber Drinking Water System	100.00%	100.00%
Scugog, Township of	Blackstock Drinking Water System	100.00%	100.00%
Scugog, Township of	Greenbank Drinking Water System	100.00%	100.00%
Scugog, Township of	Port Perry Drinking Water System	100.00%	99.91%
Severn, Township of	Bass Lake Woodlands Drinking Water System	100.00%	100.00%
Severn, Township of	Coldwater Drinking Water System	100.00%	100.00%
Severn, Township of	Sandcastle Estates Drinking Water System	100.00%	100.00%
Severn, Township of	Severn Estates Drinking Water System	100.00%	100.00%
Severn, Township of	Washago Drinking Water System	100.00%	100.00%
Severn, Township of	West Shore Drinking Water System	100.00%	100.00%
Shelburne, Town of	Shelburne Drinking Water System	99.21%	100.00%
Sioux Lookout, Municipality of	Hudson Drinking Water System	98.49%	100.00%
Sioux Lookout, Municipality of	Sioux Lookout Urban Drinking Water System	100.00%	99.73%
Smith-Ennismore-Lakefield, Township of	Lakefield Drinking Water System	100.00%	100.00%
Smith-Ennismore-Lakefield, Township of	Woodland Acres Subdivision Distribution System	100.00%	99.78%
Smiths Falls, Town of	Smiths Falls Drinking Water System	100.00%	99.89%
Smooth Rock Falls, Town of	Smooth Rock Falls Drinking Water System	91.53%	99.55%
South Bruce Peninsula, Town of	Amabel-Sauble Drinking Water System	97.37%	100.00%
South Bruce Peninsula, Town of	Foreman Drinking Water System	100.00%	100.00%
South Bruce Peninsula, Town of	Huron Woods Drinking Water System	100.00%	100.00%
South Bruce Peninsula, Town of	Oliphant Drinking Water System	100.00%	100.00%
South Bruce Peninsula, Town of	Warton Drinking Water System	100.00%	100.00%
South Bruce, Municipality of	Mildmay Drinking Water System	100.00%	100.00%
South Bruce, Municipality of	Teeswater Drinking Water System	99.16%	99.79%
South Dundas, Township of	South Dundas Regional Drinking Water System	100.00%	99.59%
South Frontenac, Township of	Sydenham Drinking Water System	100.00%	100.00%
South Glengarry, Township of	Glen Walter Drinking Water System	100.00%	100.00%
South Glengarry, Township of	Lancaster Drinking Water System	96.69%	100.00%
South Glengarry, Township of	Redwood Estates Drinking Water System	100.00%	99.21%
South Huron, Municipality of	Lake Huron Primary Water Supply System	97.35%	99.92%
South Huron, Municipality of	South Huron Distribution System	100.00%	100.00%
South River, Village of	South River Drinking Water System	90.50%	100.00%
South Stormont, Township of	Long Sault/Ingleside Regional Drinking Water System	100.00%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
South Stormont, Township of	Newington Drinking Water System	96.89%	100.00%
South Stormont, Township of	St. Andrews/Rosedale Terrace Distribution System	100.00%	100.00%
Southgate, Township of	Dundalk Drinking Water System	100.00%	100.00%
Southwest Middlesex, Municipality of	Southwest Middlesex Distribution System	99.22%	100.00%
South-West Oxford, Township of	Beachville Drinking Water System	100.00%	100.00%
South-West Oxford, Township of	Brownsville Drinking Water System	96.44%	99.74%
South-West Oxford, Township of	Dereham Centre Drinking Water System	97.50%	100.00%
South-West Oxford, Township of	Mount Elgin Drinking Water System	96.48%	100.00%
Southwold, Township of	Southwold Distribution System	100.00%	100.00%
Spanish, Town of	Spanish Drinking Water System	94.96%	99.81%
Springwater, Township of	Anten Mills Drinking Water System	100.00%	100.00%
Springwater, Township of	Del Trend Subdivision Drinking Water System	100.00%	100.00%
Springwater, Township of	Elmvale Drinking Water System	100.00%	100.00%
Springwater, Township of	Hillsdale Drinking Water System	100.00%	100.00%
Springwater, Township of	Midhurst Drinking Water System	100.00%	100.00%
Springwater, Township of	Minesing Drinking Water System	100.00%	100.00%
Springwater, Township of	Phelpston Drinking Water System	100.00%	100.00%
Springwater, Township of	Snow Valley Highlands Drinking Water System	100.00%	100.00%
Springwater, Township of	Vespra Downs Subdivision Drinking Water System	100.00%	100.00%
St. Catharines, City of	Decew Falls-Niagara Falls Drinking Water System-Decew Falls	100.00%	99.92%
St. Catharines, City of	St. Catharines Distribution System	100.00%	99.87%
St. Clair, Township of	St. Clair Distribution System	88.79%	100.00%
St. Joseph, Township of	Richards Landing Drinking Water System	100.00%	100.00%
St. Marys, Town of	St. Marys Drinking Water System	97.40%	100.00%
St. Thomas, City of	City of St. Thomas Distribution System	100.00%	99.94%
St. Thomas, City of	St. Thomas Area Secondary Water Supply System	100.00%	100.00%
Stirling-Rawdon, Township of	Stirling Drinking Water System	100.00%	100.00%
Stratford, City of	Stratford Drinking Water System	97.33%	98.98%
Strathroy-Caradoc, Township of	Strathroy-Caradoc Distribution System-Strathroy Distribution System	93.31%	100.00%
Tay, Township of	Rope Drinking Water System	100.00%	100.00%
Tay, Township of	Victoria Harbour Drinking Water System	86.16%	99.74%
Tecumseh, Town of	Tecumseh Distribution System	100.00%	100.00%
Tehkummah, Township of	South Baymouth Drinking Water System	100.00%	100.00%
Temagami, Municipality of	Temagami North Drinking Water System	96.90%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Temagami, Municipality of	Temagami South Drinking Water System	92.24%	100.00%
Temiskaming Shores, City of	Dymond Drinking Water System	93.90%	100.00%
Temiskaming Shores, City of	Haileybury Drinking Water System	92.37%	100.00%
Temiskaming Shores, City of	New Liskeard Drinking Water System	100.00%	100.00%
Terrace Bay, Township of	Terrace Bay Drinking Water System	89.86%	100.00%
Thames Centre, Municipality of	Dorchester Drinking Water System	99.50%	100.00%
Thames Centre, Municipality of	Thorndale Drinking Water System	100.00%	99.40%
The Blue Mountains, Town of	Thornbury Drinking Water System	100.00%	99.92%
The Nation, Municipality of	Limoges Drinking Water System	100.00%	100.00%
The Nation, Municipality of	St. Isidore Distribution System	100.00%	100.00%
The North Shore, Township of	Pronto East Subdivision Drinking Water System	96.31%	100.00%
The North Shore, Township of	Serpent River Drinking Water System	100.00%	98.65%
Thessalon, Town of	Thessalon Drinking Water System	100.00%	99.64%
Thorold, City of	Thorold (Decew) Distribution System	100.00%	100.00%
Thorold, City of	Thorold (Port Robinson) Distribution System	94.63%	100.00%
Thunder Bay, City of	Bare Point Road Drinking Water System	96.04%	99.83%
Tillsonburg, Town of	Tillsonburg Drinking Water System	96.17%	99.93%
Timmins, City of	Timmins Drinking Water System	100.00%	99.95%
Tiny, Township of	Bluewater Drinking Water System	100.00%	100.00%
Tiny, Township of	Castle Cove Drinking Water System	95.76%	100.00%
Tiny, Township of	Cook's Lake Drinking Water System	100.00%	100.00%
Tiny, Township of	Georgian Bay Estates Drinking Water System	100.00%	100.00%
Tiny, Township of	Georgian Sands Drinking Water System	100.00%	100.00%
Tiny, Township of	Lafontaine Drinking Water System	100.00%	100.00%
Tiny, Township of	Lefaive Drinking Water System	100.00%	100.00%
Tiny, Township of	McMahan Drinking Water System	Not available ³	Not available ³
Tiny, Township of	Pennorth Drinking Water System	100.00%	100.00%
Tiny, Township of	Perkinsfield Drinking Water System	100.00%	100.00%
Tiny, Township of	Rayko Drinking Water System	100.00%	100.00%
Tiny, Township of	Sawlog Bay Drinking Water System	100.00%	100.00%
Tiny, Township of	Tee Pee Point Drinking Water System	96.27%	100.00%
Tiny, Township of	Thunder Bay Drinking Water System	100.00%	100.00%
Tiny, Township of	Vanier Woods Drinking Water System	100.00%	100.00%
Tiny, Township of	Whip-Poor-Will Drinking Water System	96.08%	100.00%
Tiny, Township of	Woodland Beach Drinking Water System	95.57%	100.00%
Tiny, Township of	Wyevale Drinking Water System	87.27%	100.00%
Toronto, City of	City of Toronto Drinking Water System-F.J. Horgan	96.61%	100.00%

³ Inspection rating and drinking water quality data is not available for this system as it was amalgamated with the Bluewater Drinking Water System.

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Toronto, City of	City of Toronto Drinking Water System-R.C. Harris	100.00%	100.00%
Toronto, City of	City of Toronto Drinking Water System-R.L. Clark	95.31%	100.00%
Toronto, City of	City of Toronto Drinking Water System-Toronto Distribution System	100.00%	99.57%
Toronto, City of	City of Toronto Drinking Water System-Toronto Island	100.00%	99.97%
Trent Hills, Municipality of	Campbellford Drinking Water System	100.00%	100.00%
Trent Hills, Municipality of	Hastings Drinking Water System	100.00%	99.83%
Trent Hills, Municipality of	Warkworth Drinking Water System	98.41%	99.76%
Tweed, Municipality of	Tweed Drinking Water System	100.00%	100.00%
Uxbridge, Township of	Uxbridge Drinking Water System	100.00%	100.00%
Val Rita-Harty, Township of	Val Rita Drinking Water System	100.00%	100.00%
Vaughan, City of	Kleinburg Distribution System	100.00%	99.68%
Vaughan, City of	Kleinburg Drinking Water System	100.00%	100.00%
Vaughan, City of	Vaughan Distribution System	100.00%	99.79%
Warwick, Township of	Township of Warwick Distribution System	91.30%	100.00%
Wasaga Beach, Town of	Wasaga Beach Drinking Water System	100.00%	100.00%
Waterloo, City of	City of Waterloo Distribution System	100.00%	99.97%
Waterloo, City of	Region of Waterloo Drinking Water System-Waterloo	100.00%	100.00%
Wawa, Municipality of	Wawa Drinking Water System	96.92%	100.00%
Welland, City of	Welland Distribution System	100.00%	99.91%
Welland, City of	Welland Drinking Water System	100.00%	99.74%
Wellesley, Township of	Linwood Drinking Water System	100.00%	100.00%
Wellesley, Township of	St. Clements Drinking Water System	100.00%	99.79%
Wellesley, Township of	Wellesley Drinking Water System	100.00%	100.00%
Wellington North, Township of	Arthur Drinking Water System	100.00%	100.00%
Wellington North, Township of	Mount Forest Drinking Water System	100.00%	100.00%
West Elgin, Municipality of	West Elgin Drinking Water System	88.95%	99.83%
West Grey, Municipality of	Durham Drinking Water System	99.45%	100.00%
West Grey, Municipality of	Neustadt Drinking Water System	100.00%	100.00%
West Lincoln, Township of	Smithville Distribution System	82.72%	100.00%
West Nipissing, Municipality of	Sturgeon Falls Drinking Water System	95.38%	100.00%
West Nipissing, Municipality of	Verner Drinking Water System	93.56%	100.00%
West Perth, Municipality of	Mitchell Drinking Water System	100.00%	99.46%
Westport, Village of	Westport Drinking Water System	100.00%	100.00%
Whitby, Town of	Oshawa-Whitby-Ajax Drinking Water System-Whitby	100.00%	99.96%
Whitchurch-Stouffville, Town of	Ballantrae-Musselman Lake Distribution System	93.40%	100.00%

APPENDIX 1: Municipal Residential Drinking Water Systems' 2012-13 Inspection Ratings and Drinking Water Quality Results (Percentage of Tests Meeting Standards)

Municipal Location (Municipality Where the Drinking Water System is Located)	Drinking Water System Name	2012-13 Inspection Rating	2012-13 Drinking Water Quality (% Tests Meeting Standards)
Whitchurch-Stouffville, Town of	Ballantrae-Musselman's Drinking Water System	100.00%	100.00%
Whitchurch-Stouffville, Town of	Stouffville Distribution System	100.00%	99.67%
Whitchurch-Stouffville, Town of	York Drinking Water System-Stouffville	100.00%	100.00%
White River, Township of	White River Drinking Water System	100.00%	100.00%
Whitewater Region, Township of	Beachburg Drinking Water System	95.65%	100.00%
Whitewater Region, Township of	Cobden Drinking Water System	95.80%	99.78%
Whitewater Region, Township of	Haley Drinking Water System	100.00%	100.00%
Wilmot, Township of	Foxboro Drinking Water System	100.00%	100.00%
Wilmot, Township of	New Dundee Distribution System	98.78%	100.00%
Wilmot, Township of	New Dundee Drinking Water System	96.23%	100.00%
Wilmot, Township of	New Hamburg-Baden Distribution System	100.00%	99.89%
Wilmot, Township of	Region of Waterloo Drinking Water System -Shingletown	100.00%	100.00%
Wilmot, Township of	Region of Waterloo Drinking Water System-Mannheim Village	100.00%	100.00%
Wilmot, Township of	Region of Waterloo Drinking Water System-New Hamburg-Baden	100.00%	100.00%
Wilmot, Township of	St. Agatha Distribution System	100.00%	100.00%
Windsor, City of	City of Windsor Drinking Water System	100.00%	99.92%
Woodstock, City of	Woodstock Drinking Water System	97.58%	99.64%
Woolwich, Township of	Conestogo Golf Distribution System	100.00%	100.00%
Woolwich, Township of	Conestogo Golf Drinking Water System	100.00%	100.00%
Woolwich, Township of	Conestogo Plains Distribution System	100.00%	99.69%
Woolwich, Township of	Conestogo Plains Drinking Water System	100.00%	100.00%
Woolwich, Township of	Elmira-St. Jacobs-Breslau Distribution System-Breslau Distribution System	97.71%	99.15%
Woolwich, Township of	Elmira-St. Jacobs-Breslau Distribution System-Elmira-St. Jacobs Distribution System	98.11%	99.86%
Woolwich, Township of	Heidelberg Distribution System	100.00%	99.69%
Woolwich, Township of	Heidelberg Drinking Water System	100.00%	100.00%
Woolwich, Township of	Maryhill Drinking Water System-Maryhill	100.00%	100.00%
Woolwich, Township of	Maryhill Drinking Water System-Maryhill Village Heights	100.00%	100.00%
Woolwich, Township of	Maryhill Heights Distribution System	100.00%	100.00%
Woolwich, Township of	Maryhill Isley Distribution System	100.00%	100.00%
Woolwich, Township of	West Montrose Distribution System	100.00%	100.00%
Woolwich, Township of	West Montrose Drinking Water System	95.17%	100.00%
Zorra, Township of	Embro Drinking Water System	100.00%	100.00%
Zorra, Township of	Lakeside Drinking Water System	94.24%	100.00%
Zorra, Township of	Thamesford Drinking Water System	94.53%	100.00%

APPENDIX 2-A-1: Summary of Municipal Residential Drinking Water Systems Receiving Contravention Orders as a Result of an Inspection in 2012-13

DRINKING WATER SYSTEM OWNER	DRINKING WATER SYSTEM NAME	DATE ORDER ISSUED	ORDER SYNOPSIS
Atikokan, The Corporation of the Town of	Atikokan Drinking Water System	May 27, 2013	<ul style="list-style-type: none"> • Provide a report on the status of the chlorinator, and review of the flow features of the fluoride system. • Provide a report describing what actions have been taken to ensure that data from the continuous analyzers is recorded and kept for the required period of time. • Confirm whether the installation of the raw water flow meters meets the manufacturer's requirements. • Confirm that flow monitoring data is being recorded correctly for raw water flow meters.
Greenstone, The Corporation of the Municipality of	Geraldton Drinking Water System	April 18, 2013	<ul style="list-style-type: none"> • The conventional filtration process did not meet the design requirements of the "Procedure for Disinfection of Drinking Water in Ontario". • Chlorine contact time calculations were based on an incorrect detention time of water in the clearwells. • Treatment equipment for gas chlorination and chemical addition were not in operation whenever water was being supplied. Following the response to an alarm related to the loss of chlorination, the operator-in-charge did not take appropriate actions and did not monitor the situation. The operator in charge did not ensure that records were made of all adjustments to the process. • During periods when primary and secondary disinfection were not maintained, the operating authority did not immediately take measures to notify users to use an alternate supply of water or to boil the water. • Reports of loss of disinfection were not immediately provided to the medical officer of health and the ministry.

APPENDIX 2-A-2: Summary of Municipal Residential Drinking Water Systems Receiving Contravention Orders as a Result of an Incident in 2012-13

DRINKING WATER SYSTEM OWNER	DRINKING WATER SYSTEM NAME	DATE ORDER ISSUED	ORDER SYNOPSIS
Tiny, The Corporation of the Township of	McMahan Drinking Water System	November 14, 2012	<ul style="list-style-type: none"> • Requirements of the order included, for example, sampling and testing the drinking water according to legislation. The municipality amalgamated this system with the Bluewater Drinking Water System and this system ceased to operate.

APPENDIX 2-B: Summary of Municipal Residential Drinking Water Systems Receiving Preventative Measures Orders as a Result of an Incident in 2012-13

DRINKING WATER SYSTEM OWNER	DRINKING WATER SYSTEM NAME	DATE ORDER ISSUED	ORDER SYNOPSIS
Emo, The Corporation of the Township of	Emo Drinking Water System	May 14, 2012	<ul style="list-style-type: none"> To grant the Emo Water Treatment Plant relief from strict compliance during the installation of new turbidity analyzers. The owner is not required to continuously monitor filter effluent turbidity and the plant is not required to be equipped with a high turbidity alarm during the maintenance work.
Ignace, The Corporation of the Township of	Ignace Drinking Water System	January 18, 2013	<ul style="list-style-type: none"> To grant the Ignace Water Treatment Plant relief from strict compliance until the treated water flow meter is operational. The owner and operating authority are not required to continuously monitor and record the flow rate and daily volume of treated water that flows from the treatment subsystem to the distribution system until then.
Kenora Association for Community Living	Kenora Area Drinking Water System	September 20, 2012	<ul style="list-style-type: none"> Remove the terminating end of the existing watermain from the sewer manhole and ensure that the separation distance between the main and the manhole conforms with the standards recommended by the ministry. Implement the following mitigating measures to the area potentially impacted by the cross-connection: (a) increase bacteriological sampling and chlorine residual testing; (b) collect complaint records (if any) and review them for any trends; (c) ensure appropriately trained staff monitor the condition of the watermain in the sewer manhole and document their observations; (d) ensure the municipality's emergency plan for reacting to watermain breaks or pressure losses is activated immediately. Have a qualified person survey Kenora's water distribution system for cross-connections in the sewer manholes.
Pickle Lake, The Corporation of the Township of	Pickle Lake Drinking Water System	July 12, 2012	<ul style="list-style-type: none"> To grant the Pickle Lake Drinking Water system relief from strict compliance due to a lightning strike which disabled chlorine alarms within the plant. The owners shall demonstrate that operators are manually checking free chlorine residuals and notify the ministry, as soon as possible, of the presence of bacteria in raw water samples.

DRINKING WATER SYSTEM OWNER	DRINKING WATER SYSTEM NAME	DATE ORDER ISSUED	ORDER SYNOPSIS
Red Lake, The Municipality of	Red Lake Drinking Water System	July 9, 2012	<ul style="list-style-type: none"> To grant the Red Lake Water Treatment Plant relief from strict compliance until the system's new Supervisory Control and Data Acquisition system is installed and operational. The owner is not required to continuously monitor and record the flow rate and daily volume of treated water that flows from the treatment subsystem to the distribution system.
Sioux Lookout, The Corporation of the Municipality of	Sioux Lookout Urban Drinking Water System	August 30, 2012	<ul style="list-style-type: none"> To grant the Sioux Lookout Urban Drinking Water System relief from strict compliance until the new raw and treated water flow meters are installed and operational at the plant. The owner and operating authority are not required to continuously monitor and record the flow rate and daily volume of treated water that flows from the treatment subsystem to the distribution system.

APPENDIX 2-C-1: Summary of Laboratories Licensed to Perform Drinking Water Testing Receiving Contravention Orders in 2012-13

MUNICIPAL LOCATION	LABORATORY NAME	DATE ORDER ISSUED	ORDER SYNOPSIS
Mississauga, City of	Maxxam Analytics International Corporation	June 20, 2012	<ul style="list-style-type: none"> Cease providing drinking water testing services for a specific parameter without a licence. Ensure policies and procedures are in place and understood by staff, who have customer service responsibilities, regarding the acceptance and testing of drinking water samples for which the laboratory does not hold a Drinking Water Testing Licence. Provide a copy of the relevant policies, procedures and records that demonstrate the aforementioned staff have been trained on the policies and procedures.

APPENDIX 2-C-2: Summary of Non-licensed Facilities Receiving Contravention Orders in 2012-13

MUNICIPAL LOCATION	LABORATORY NAME	DATE ORDER ISSUED	ORDER SYNOPSIS
London, City of	GAP EnviroMicrobial Services Ltd.	September 17, 2012	<ul style="list-style-type: none"> Cease and desist providing drinking water testing services and analysing Ontario drinking water samples without a Drinking Water Testing Licence.

APPENDIX 3: Summary of Municipal Residential Drinking Water System Convictions – April 1, 2012 to March 31, 2013

OWNER AND/ OR OPERATOR OF DRINKING WATER SYSTEM	SYSTEM NAME	SYNOPSIS	CHARGES LAID	CONVICTION	FINE
North Middlesex, The Corporation of the Municipality of	North Middlesex Distribution System	Failing to collect bacteriological samples following watermain repairs and operating a water system without a valid operator's certificate	December 6, 2012	March 11, 2013	\$17,000.00 ¹
West Elgin, The Corporation of the Municipality of	West Elgin Water Treatment Plant	Failing to ensure that persons who carry out functions in relation to the drinking water system comply with reporting requirements	April 29, 2011	October 22, 2012	\$154,500.00 ¹
PUC Services Inc.	Blind River Water Treatment Plant	Failure to report that raw water had not been disinfected in accordance with the ministry's "Procedure for Disinfection of Drinking Water in Ontario" on several occasions	November 22, 2012	February 13, 2013	\$15,000.00
Total					\$186,500.00

¹ Includes, five individuals, three of whom were convicted for violations at the West Elgin Water Treatment Plant and two of whom were convicted for violations at the North Middlesex Distribution System.